


The Remote Sensing Technologies Project



Report of Calibration No. OSL / 3542
Camera No. 142826
Lens No. 142819



United States Department of the Interior

U.S. GEOLOGICAL SURVEY
Reston, Virginia 20192

REPORT OF CALIBRATION of Aerial Mapping Camera

December 01, 2010

Camera type: Zeiss RMK Top 15*
Lens type: Zeiss Pleogon A3/4
Nominal focal Length: 153 mm

Camera serial no.: 142826
Lens serial no.: 142819
Maximum aperture: f/4
Test aperture: f/4

Submitted by: James W. Sewall Co.
Old Town, ME

Reference:

These measurements were made on Agfa glass plates, 0.19 inch thick, with spectroscopic emulsion type APX Panchromatic, developed in D-19 at 68° F for 3 minutes with continuous agitation. These photographic plates were exposed on a multicollimator camera calibrator using a white light source rated at approximately 5200K.

I. Calibrated Focal Length: 153.542 mm

II. Lens Distortion

Field angle:	7.5°	15°	22.7°	30°	35°	40°
Symmetric radial (μm)	0	0	0	-1	-1	1
Decentering tangential (μm)	0	0	1	2	3	4

<u>Symmetric radial distortion</u>		<u>Decentering distortion</u>		<u>Calibrated principal point</u>	
K_0	= 0.2297E-05	P_1	= -0.7028E-07	x_p	= 0.002 mm
K_1	= 0.1800E-08	P_2	= -0.2237E-06	y_p	= -0.005 mm
K_2	= -0.1364E-12	P_3	= 0.0000		
K_3	= 0.0000	P_4	= 0.0000		
K_4	= 0.0000				

The values and parameters for Calibrated Focal Length (CFL), Symmetric Radial Distortion (K_0, K_1, K_2, K_3, K_4), Decentering Distortion (P_1, P_2, P_3, P_4), and Calibrated Principal Point [point of symmetry] (x_p, y_p) were determined through a least-squares Simultaneous Multiframe Analytical Calibration (SMAC) adjustment. The x and y-coordinate measurements utilized in the adjustment of the above parameters have a standard deviation (σ) of ± 3 microns.

* Equipped with Forward Motion Compensation

III. Lens Resolving Power in cycles/mm

Area-weighted average resolution: 97

Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	159	159	134	95	95	80	95
Tangential Lines	159	134	113	95	95	80	95

The resolving power is obtained by photographing a series of test bars and examining the resultant image with appropriate magnification to find the spatial frequency of the finest pattern in which the bars can be counted with reasonable confidence. The series of patterns has spatial frequencies from 5 to 268 cycles/mm in a geometric series having a ratio of the 4th root of 2. Radial lines are parallel to a radius from the center of the field, and tangential lines are perpendicular to a radius.

IV. Filter Parallelism

The two surfaces of the USGS TOP 15 test filter KL-F (60%) No. 142399 are within 10 seconds of being parallel. This filter, in conjunction with the internal "B" filter, was used for the calibration.

V. Shutter Calibration

Indicated Time (sec)	Rise Time (μ sec)	Fall Time (μ sec)	$\frac{1}{2}$ Width Time (ms)	Nom. Speed (sec)	Efficiency (%)
1/100	3022	3086	12.22	1/100	84
1/200	1537	1516	6.01	1/200	84
1/300	940	935	3.71	1/320	84
1/400	655	663	2.69	1/440	85
1/500	519	535	2.10	1/560	84

The effective exposure times were determined with the lens at aperture f/4. The method is considered accurate within 3 percent. The technique used is described in International Standard ISO 516:1999(E).

VI. Magazine Platen

The platen mounted in Zeiss CC-24 film magazine No. 136187 does not depart from a true plane by more than 13 μ m (0.0005 in).


The platen for this film magazine is equipped with an identification marker that will register "CZ399" in the data strip area for each exposure.

VII. Principal Point and Fiducial Mark Coordinates

d
a
t
a

s
t
r
i
p

s
i
d
e



Positions of all points are referenced to the principal point of autocollimation (PPA) as origin. The diagram indicates the orientation of the reference points when the camera is viewed from the back, or a contact positive with the emulsion up. The data strip is to the left.

	<u>X coordinate (mm)</u>	<u>Y coordinate (mm)</u>
Indicated principal point, corner fiducials	0.021	0.005
Indicated principal point, midside fiducials	0.015	0.007
Principal point of autocollimation (PPA)	0.000	0.000
Calibrated principal point (point of symmetry)	0.002	-0.005
<u>Fiducial Marks</u>		
1	-112.990	-112.992
2	113.025	112.995
3	-112.962	113.004
4	113.001	-112.992
5	-112.969	0.004
6	113.027	0.010
7	0.033	113.007
8	-0.003	-113.000

VIII. Distances Between Fiducial marks

Corner fiducials (diagonals)	1-2: 319.613 mm	3-4: 319.582 mm
Lines joining these markers intersect at an angle of 89° 59' 58"		
Midside fiducials	5-6: 225.995 mm	7-8: 226.007 mm
Lines joining these markers intersect at an angle of 89° 59' 22"		
Corner fiducials (perimeter)	1-3: 225.995 mm	2-3: 225.987 mm
	1-4: 225.990 mm	2-4: 225.987 mm

The Method of measuring these distances is considered accurate within 0.003 mm

Note: For GPS applications, the nominal entrance pupil distance from the focal plane is 254mm with a 10 mm filter thickness. Additional filter thickness will increase entrance pupil distance by 0.34 X added thickness.


IX. Stereomodel Flatness

FMC Magazine No: 136187

Base/Height ratio: 0.6

Platen ID: CZ399

Maximum angle of field tested: 40°



Stereomodel Test Point Array
(values in micrometers)

The values shown on the diagram are the average departures from flatness (at negative scale) for two computer-simulated stereo models. The values are based on comparator measurements on Agfa Avitone P3P copy film made from Kodak 2405 film exposures. These measurements are considered accurate to within 5 μm .

X. System Resolving Power on film in cycles/mm

Area-weighted average resolution: 47

Film: Type 2405

Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	57	57	57	48	48	48	40
Tangential Lines	57	57	48	48	48	40	40

This aerial mapping camera calibration report supersedes the previously issued USGS Report No. OSL/3356, dated November 16, 2007.

Michael G. Benson
Remote Sensing Technologies Project Manager
Geography Discipline