

United States Department of the Interior

U.S. GEOLOGICAL SURVEY
 Reston, Virginia 20192

REPORT OF CALIBRATION of Aerial Mapping Camera

September 20, 2007

Camera type:	Wild RC30*	Camera serial no.:	5253
Lens type:	Wild Universal Aviogon /4-S	Lens serial no.:	13261
Nominal focal Length:	153 mm	Maximum aperture:	f/4
		Test aperture:	f/4
Submitted by:	Richard Crouse & Associates, Inc. Frederick, Maryland		
Reference:	Richard Crouse & Associates, Inc. purchase order No. 0735, dated September 19, 2007.		

These measurements were made on Agfa glass plates, 0.19 inch thick, with spectroscopic emulsion type APX Panchromatic, developed in D-19 at 68° F for 3 minutes with continuous agitation. These photographic plates were exposed on a multicollimator camera calibrator using a white light source rated at approximately 5200K.

I. Calibrated Focal Length: 153.398 mm

II. Lens Distortion

Field angle:	7.5°	15°	22.7°	30°	35°	40°
Symmetric radial (µm)	0	-1	-3	-4	-3	4
Decentering tangential (µm)	0	0	1	2	3	5

<u>Symmetric radial distortion</u>		<u>Decentering distortion</u>		<u>Calibrated principal point</u>	
K_0	= 0.1407E-04	P_1	= -0.1250E-06	x_p	= 0.006 mm
K_1	= 0.1092E-07	P_2	= 0.2534E-06	y_p	= -0.002 mm
K_2	= -0.8274E-12	P_3	= 0.0000		
K_3	= 0.0000	P_4	= 0.0000		
K_4	= 0.0000				

The values and parameters for Calibrated Focal Length (CFL), Symmetric Radial Distortion (K_0, K_1, K_2, K_3, K_4), Decentering Distortion (P_1, P_2, P_3, P_4), and Calibrated Principal Point [point of symmetry] (x_p, y_p) were determined through a least-squares Simultaneous Multiframe Analytical Calibration (SMAC) adjustment. The x and y-coordinate measurements utilized in the adjustment of the above parameters have a standard deviation (σ) of ± 3 microns.

* Equipped with Forward Motion Compensation

III. Lens Resolving Power in cycles/mm

Area-weighted average resolution: 108

Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	113	134	134	113	113	95	95
Tangential Lines	113	134	113	113	113	95	95

The resolving power is obtained by photographing a series of test bars and examining the resultant image with appropriate magnification to find the spatial frequency of the finest pattern in which the bars can be counted with reasonable confidence. The series of patterns has spatial frequencies from 5 to 268 cycles/mm in a geometric series having a ratio of the 4th root of 2. Radial lines are parallel to a radius from the center of the field, and tangential lines are perpendicular to a radius.

IV. Filter Parallelism

The two surfaces of the Wild 525 filter No. 7546 accompanying this camera are within 10 seconds of being parallel. This filter was used for the calibration.

V. Shutter Calibration

Indicated Time (sec)	Rise Time (μ sec)	Fall Time (μ sec)	$\frac{1}{2}$ Width Time (ms)	Nom. Speed (sec)	Efficiency (%)
1/125	1725	1739	8.36	1/140	87
1/250	874	863	4.18	1/270	87
1/500	430	422	2.12	1/540	87
1/1000	227	220	1.08	1/1060	87

The effective exposure times were determined with the lens at aperture f/4. The method is considered accurate within 3 percent. The technique used is described in International Standard ISO 516:1999(E).


VI. Film Platen

The platen mounted in Wild drive unit No. 5253-616 does not depart from a true plane by more than 13 μ m (0.0005 in).

This camera is equipped with a platen identification marker that will register "616" in the data strip area for each exposure.

VII. Principal Point and Fiducial Mark Coordinates

data strip inside



Positions of all points are referenced to the principal point of autocollimation (PPA) as origin. The diagram indicates the orientation of the reference points when the camera is viewed from the back, or a contact positive with the emulsion up. The data strip is to the left.

	<u>X coordinate (mm)</u>	<u>Y coordinate (mm)</u>
Indicated principal point, corner fiducials	.000	.022
Indicated principal point, midside fiducials	.000	.017
Principal point of autocollimation (PPA)	.000	.000
Calibrated principal point (point of symmetry)	.006	-.002
<u>Fiducial Marks</u>		
1	-106.004	-105.980
2	106.000	106.019
3	-105.997	106.019
4	106.001	-105.980
5	-112.005	.016
6	112.002	.018
7	.003	112.030
8	-.003	-111.988

VIII. Distances Between Fiducial marks

Corner fiducials (diagonals)	1-2: 299.815 mm	3-4: 299.811 mm
Lines joining these markers intersect at an angle of 90° 00' 02"		
Midside fiducials	5-6: 224.007 mm	7-8: 224.018 mm
Lines joining these markers intersect at an angle of 89° 59' 53"		
Corner fiducials (perimeter)	1-3: 211.999 mm	2-3: 211.996 mm
	1-4: 212.004 mm	2-4: 211.999 mm

The Method of measuring these distances is considered accurate within 0.003 mm

Note: For GPS applications, the nominal entrance pupil distance from the focal plane is 283 mm.


IX. Stereomodel Flatness

FMC Drive Unit No: 5253-616

Base/Height ratio: 0.6

Platen ID: 616

Maximum angle of field tested: 40°



Stereomodel Test Point Array
(values in micrometers)

The values shown on the diagram are the average departures from flatness (at negative scale) for two computer-simulated stereo models. The values are based on comparator measurements on Kodak 4425 copy film made from Kodak 2405 film exposures. These measurements are considered accurate to within 5 μm.


X. System Resolving Power on film in cycles/mm

Area-weighted average resolution: 51

Film: Type 2405

Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	57	57	57	57	57	48	48
Tangential Lines	57	57	48	48	48	48	48

This aerial mapping camera calibration report supersedes the previously issued USGS Report No. OSL/3056, dated June 29, 2004.


 Gregory L. Stensaas
 Remote Sensing Technologies Project Manager
 Geography Discipline