



United States Department of the Interior

U.S. GEOLOGICAL SURVEY
Reston, Virginia 20192

REPORT OF CALIBRATION of Aerial Mapping Camera

September 12, 2013

Camera type:	Wild RC30*	Camera serial no.:	5296
Lens type:	Wild Universal Aviogon /4-S	Lens serial no.:	13433
Nominal focal Length:	153 mm	Maximum aperture:	f/4
		Test aperture:	f/4
Submitted by:	Richard Crouse & Associates Frederick, Maryland		

Reference:

These measurements were made on Agfa glass plates, 0.19 inch thick, with spectroscopic emulsion type APX Panchromatic, developed in D-19 at 68° F for 3 minutes with continuous agitation. These photographic plates were exposed on a multicollimator camera calibrator using a white light source rated at approximately 5200K.

I. Calibrated Focal Length: 153.664 mm

II. Lens Distortion

Field angle:	7.5°	15°	22.7°	30°	35°	40°
Symmetric radial (μm)	1	2	3	3	1	-3
Decentering tangential (μm)	0	0	1	1	2	3

Symmetric radial distortion	Decentering distortion	Calibrated principal point
$K_0 = -0.5476\text{E-}04$	$P_1 = -0.1470\text{E-}06$	$x_p = 0.001 \text{ mm}$
$K_1 = 0.1885\text{E-}08$	$P_2 = -0.8855\text{E-}07$	$y_p = 0.013 \text{ mm}$
$K_2 = 0.1598\text{E-}12$	$P_3 = 0.0000$	
$K_3 = 0.0000$	$P_4 = 0.0000$	
$K_4 = 0.0000$		

The values and parameters for Calibrated Focal Length (CFL), Symmetric Radial Distortion (K_0, K_1, K_2, K_3, K_4), Decentering Distortion (P_1, P_2, P_3, P_4), and Calibrated Principal Point [point of symmetry] (x_p, y_p) were determined through a least-squares Simultaneous Multiframe Analytical Calibration (SMAC) adjustment. The x and y-coordinate measurements utilized in the adjustment of the above parameters have a standard deviation (σ) of ± 3 microns.

* Equipped with Forward Motion Compensation

III. Lens Resolving Power in cycles/mm

Area-weighted average resolution: 114

<u>Field angle:</u>	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	134	159	134	113	134	113	95
Tangential Lines	134	134	134	113	113	95	95

The resolving power is obtained by photographing a series of test bars and examining the resultant image with appropriate magnification to find the spatial frequency of the finest pattern in which the bars can be counted with reasonable confidence. The series of patterns has spatial frequencies from 5 to 268 cycles/mm in a geometric series having a ratio of the 4th root of 2. Radial lines are parallel to a radius from the center of the field, and tangential lines are perpendicular to a radius.

IV. Filter Parallelism

The two surfaces of the Wild 420 filter No. 7980 and 525 filter No. 7765 accompanying this camera are within 10 seconds of being parallel. The 525 filter was used for the calibration.

V. Shutter Calibration

<u>Indicated Time</u> (sec)	<u>Rise Time</u> (μ sec)	<u>Fall Time</u> (μ sec)	<u>½ Width Time</u> (ms)	<u>Nom. Speed</u> (sec)	<u>Efficiency</u> (%)
1/125	819	818	9.16	1/120	94
1/250	401	391	4.75	1/220	95
1/500	201	199	2.40	1/440	95
1/1000	104	98	1.21	1/870	95


The effective exposure times were determined with the lens at aperture $f/4$. The method is considered accurate within 3 percent. The technique used is described in International Standard ISO 516:1999(E).

VI. Film Platen

The platen mounted in Wild drive unit No. 5296 does not depart from a true plane by more than 13 μ m (0.0005 in).

This camera is equipped with a platen identification marker that will register "669" in the data strip area for each exposure.

VII. Principal Point and Fiducial Mark Coordinates



Positions of all points are referenced to the principal point of autocollimation (PPA) as origin. The diagram indicates the orientation of the reference points when the camera is viewed from the back, or a contact positive with the emulsion up. The data strip is to the left.

Indicated principal point, corner fiducials
 Indicated principal point, midside fiducials
 Principal point of autocollimation (PPA)
 Calibrated principal point (point of symmetry)

X coordinate (mm) Y coordinate (mm)

-0.003	0.011
-0.006	0.011
0.000	0.000
0.001	0.013

Fiducial Marks

1	-105.997	-105.987
2	105.994	106.014
3	-106.007	106.010
4	106.001	-105.987
5	-111.999	0.012
6	111.997	0.011
7	-0.009	112.005
8	-0.003	-111.983

VIII. Distances Between Fiducial marks

Corner fiducials (diagonals)	1-2: 299.808 mm	3-4: 299.816 mm
Lines joining these markers intersect at an angle	o 90° 00' 00"	
Midside fiducials	5-6: 223.995 mm	7-8: 223.989 mm
Lines joining these markers intersect at an angle	o 90° 00' 07"	
Corner fiducials (perimeter)	1-3: 211.997 mm	2-3: 212.001 mm
	1-4: 211.998 mm	2-4: 212.001 mm

The Method of measuring these distances is considered accurate within 0.003 mm

Note: For GPS applications, the nominal entrance pupil distance from the focal plane is 277mm.


IX. Stereomodel Flatness

FMC Drive Unit No: 5296

Platen ID: 669

Base/Height ratio: 0.6

Maximum angle of field tested: 40°



Stereomodel Test Point Array
(values in micrometers)

The values shown on the diagram are the average departures from flatness (at negative scale) for two computer-simulated stereo models. The values are based on comparator measurements on Agfa Avitone P3p copy film made from Agfa Aviphot Pan 200 film exposures. These measurements are considered accurate to within 5 μm.

X. System Resolving Power on film in cycles/mm

Area-weighted average resolution: 54

Film: Pan 200

Field angle:	0°	7.5°	15°	22.7°	30°	35°	40°
Radial Lines	57	57	57	57	57	57	48
Tangential Lines	57	57	57	57	57	48	40

This aerial mapping camera calibration report supersedes the previously issued USGS Report No. OSL/3408, dated September 22, 2008.

Wayne A. Miller
Long Term Archive Project Manager
Climate and Land Use Change